
From: Leonard C Pope (Generation - 34) [/O=DOMINION/OU=EXCHANGE ADMINISTRATIVE GROUP (FYDIBOHF23SPDLT)/CN=RECIPIENTS/CN=LEONA5286E]
Sent: 3/24/2015 4:26:40 PM
To: Bob Jackson (Generation - 34) [/O=DOMINION/OU=EXCHANGE ADMINISTRATIVE GROUP (FYDIBOHF23SPDLT)/CN=RECIPIENTS/CN=Robe218]; Michael A Glagola (Generation - 34) [/O=DOMINION/OU=EXCHANGE ADMINISTRATIVE GROUP (FYDIBOHF23SPDLT)/CN=RECIPIENTS/CN=Mic0210]
Subject: RE: Response to RFQ--Possum Point Mechanical Dredge

Mr. Michael MR. Bob here are some questions I have about the Glover Cons Co Bid are they bring their own equipment operators ,I did not see any perdiem rates for people, are the dewatering equipment rental rates pumps generators based on 24 HR operation, surface water removal by others ?. I may have missed vegetation removal/separation from ash, no water will be pumped into E pond during construction page17 9- assumptions and exclusions , what if there is high iron or other fouling agents around well points. Will PPPS be responsible for sampling the water ,With the potential for a fair amount of overtime are the equipment and labor rates based on a 40 HR work week or maybe it is not broke out. Disc charge pipe erosion in d pond. This proposal is very workable the only concern would be how much well water will go to D pond and what could be done with this water if there are excess amounts.

Leonard "Whitey" C Pope

Dominion Lead

possum point

Cell PH 804-854-3359

Leonard.C Pope@Dom.Com

From: Bob Jackson (Generation - 34)
Sent: Monday, March 23, 2015 9:44 PM
To: Leonard C Pope (Generation - 34)
Cc: Michael A Glagola (Generation - 34)
Subject: FW: Response to RFQ--Possum Point Mechanical Dredge

Whitey,

Here is the Glover bid

Ditto on comments to Mike

From: Michael A Glagola (Generation - 34)
Sent: Monday, March 23, 2015 4:45 PM
To: Bob Jackson (Generation - 34)
Subject: FW: Response to RFQ--Possum Point Mechanical Dredge

FYI

From: John Glover [<mailto:jglover@gloverconstruction.com>]
Sent: Monday, March 23, 2015 4:02 PM
To: Michael A Glagola (Generation - 34)
Cc: Nicole D Jeter (Services - 6)
Subject: Response to RFQ--Possum Point Mechanical Dredge

Mike,

We are pleased to provide you with a response to the Possum Point Mechanical Dredge RFQ. We appreciate the opportunity to respond to this quote. If you have any questions or concerns please do not hesitate to contact me.

Thank you,

--

John Glover

Glover Construction

(252)536-2660 (office)

(252)676-9003 (cell)

00011707